

Biodiesel

Manufacturer's Affirmative Statement of Compatibility
(As required by California code of Regulations section 2631 (k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years Manufactured	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test data & Documents Attached
Emco Wheaton	A1004 series	Spill Bucket	MH21149	1996-2012	All	No	BO-B100	Yes
Emco Wheaton	A0060	Shear Valve	MH6518	1996-2012	1 ½ npt	PN, EMCO cast in	B0-B20	Yes
Emco Wheaton	A0063EVR	Vapor Shear Valve	MH10206	1996-2012	1 ½ npt	PN, EMCO cast in	B0-B20	Yes
Emco Wheaton	A1004EVR Series	Spill Bucket	MH21149	2006-2012	All	ID Tag	BO-B100	Yes
Emco Wheaton	A0030-124S	Fill Swivel Adapter		2006-2012	All	PN Etched	B0-B20	
Emco Wheaton	A0076-124S	Vapor Swivel Adapter		2006-2012	All	PN Etched	B0-B20	
Emco Wheaton	A0030-014	ATG Adapter		1996-2012	All	PN Etched	B0-B20	
Emco Wheaton	A0097-005	Fill Cap		1996-2012	All	Silver, Aluminum	BO-B100	
Emco Wheaton	A0097-010	ATG Cap		1996-2012	All	Silver, Aluminum	BO-B100	
Emco Wheaton	A0099-002	Vapor Cap		1996-2012	All	Orange Aluminum	BO-B100	
Emco Wheaton	A1100EVR Series	Overfill Valve	MH21164	1996-2012	All	Etched Cover Plate	B0-B20	Yes
Emco Wheaton	A0020EVR	Drop Tube		1996-2012	All	Label	B0-B20	
Emco Wheaton	A0020EVR	Drop Tube		1996-2012	All	Label	B0-B20	
Emco Wheaton	494096	Riser seal		2006-2012	All	No	BO-B100	
Emco Wheaton	A0084	PV Vent	MH46838	1996-2012	All	Label	BO-B100	Yes
Emco Wheaton	A0075	Ball Float		1996-2012	All	No	B0-B20	
Emco Wheaton	A0079	Extractor	MH27242	1996-2012	All	PN Cast In	BO-B100	Yes

Biodiesel

Manufacturer's Affirmative Statement of Compatibility
(As required by California code of Regulations section 2631 (k))

Manufacturer: Emco Wheaton Retail Inc
Corporate 2300 Industrial Park Drive
Headquarters Wilson, NC 27893
Address:
Phone: 252 243 0150
Email: ewb@emcoretail.com



I declare, to the best of my knowledge and belief, that this affirmative statement of compatibility and the information contained herein is true, correct, and complete.

Wayne Boyd
Print Name

Director of Engineering and Quality
Title

Wayne Boyd
Manufacturer's Authorized Signature

10/23/2012
Date



EGYHC.MH21149
Spill Containment Devices for Flammable Liquid Storage Tanks

[Page Bottom](#)

Spill Containment Devices for Flammable Liquid Storage Tanks

[See General Information for Spill Containment Devices for Flammable Liquid Storage Tanks](#)

EMCO WHEATON RETAIL CORP

MH21149

2300 INDUSTRIAL PARK DR
WILSON, NC 27893 USA

Spill containment devices, Models A1004, A1005, in 19 L, 57 L and 95 L capacities; Models A1004-210S (19L), A1004-215S (57L), A1004-316S (19L) for underground applications.

[Last Updated](#) on 2010-05-28

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2011 Underwriters Laboratories of Canada Inc.](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.





EUCV.MH6518
Shutoff Valves, Emergency

[Page Bottom](#)

Shutoff Valves, Emergency

[See General Information for Shutoff Valves, Emergency](#)

EMCO WHEATON RETAIL CORP

MH6518

2300 INDUSTRIAL PARK DR
WILSON, NC 27893 USA

Model A0060.

[Last Updated](#) on 2011-06-08

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2011 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge





YUNT.MH10206
Vapor Recovery System Accessories, Flammable Liquid

[Page Bottom](#)

Vapor Recovery System Accessories, Flammable Liquid

[See General Information for Vapor Recovery System Accessories, Flammable Liquid](#)

EMCO WHEATON RETAIL CORP

MH10206

2300 INDUSTRIAL PARK DR
WILSON, NC 27893 USA

Coaxial splitter fitting, Models A4041, A4043.

Flow regulator, Model A10.

In line check valve, Model A0066-020.

Vacuum/pressure breather vent and cap, Model A84; Model A4103 vent cap.

Vapor recovery vapor valve, Model A228-001.

Vapor shear valve, Model A0063-024.

Vapor valves, Models A225-001, -002, -003, A226-001, -002.

[Last Updated](#) on 2007-07-18

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge



**EGXYC.MH21164
Overfill Protection Devices**[Page Bottom](#)**Overfill Protection Devices**[See General Information for Overfill Protection Devices](#)

EMCO WHEATON RETAIL CORP
2300 INDUSTRIAL PARK DR
WILSON, NC 27893 USA

MH21164

Model A1100 Guardian, Type B overfill protection device for use with petroleum products including fuel blends with a maximum content of 15% MIBE. Maximum flow 500 l/min, maximum pressure 45 kPa.

[Last Updated](#) on 2003 12 16[Questions?](#)[Notice of Disclaimer](#)[Page Top](#)[Copyright © 2008 Underwriters' Laboratories of Canada®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the Online Certifications Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories of Canada" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories of Canada®"

An independent organization working for a safer world with integrity, precision and knowledge



**EGVV.MH46838****Tank Accessories for Flammable and Combustible Liquids**[Page Bottom](#)

Tank Accessories for Flammable and Combustible Liquids[See General Information for Tank Accessories for Flammable and Combustible Liquids](#)**EMCO WHEATON RETAIL CORP**

MH46838

2300 INDUSTRIAL PARK DR
WILSON, NC 27893 USA**Vacuum/pressure breather vent and cap, Model A84.****Vent cap, Model A4103.**Last Updated on 2008-10-13

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2012 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2012 UL LLC".



ONLINE DIRECTORIES

EGXPC.MH27242

Miscellaneous Tank Accessories for Flammable and Combustible Liquid Tanks

[Page Bottom](#)

Miscellaneous Tank Accessories for Flammable and Combustible Liquid Tanks

[See General Information for Miscellaneous Tank Accessories for Flammable and Combustible Liquid Tanks](#)

EMCO WHEATON RETAIL CORP

MH27242

2300 INDUSTRIAL PARK DR
WILSON, NC 27893 USA

Tank Accessories: Fill adapter Model A30, vapor adapter Model A76, float valve extractor assembly Model A79 and monitoring well manhole for underground tanks Model A722.

[Last Updated](#) on 2003-12-10

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2008 Underwriters' Laboratories of Canada®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the Online Certifications Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories of Canada" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories of Canada®"

An independent organization working for a safer world with integrity, precision and knowledge

